

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1 2</div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0005</div>		3. EFFECTIVE DATE <div style="text-align: center;">16-Jan-2003</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W81G67-1344-0028</div>		5. PROJECT NO. (If applicable)	
6. ISSUED BY CONTRACTING DIVISION USACE - ST 190 5TH STREET ST PAUL MN 55101-4000		CODE <div style="text-align: center;">DACW37</div>		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center; font-weight: bold;">See Item 6</div>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. DACW37-03-B-0001			
				<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) 17-Dec-2002			
				10A. MOD. OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The bid opening date has not changed. The amendment highlights some technical information and updates the bid notes.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED	

SUMMARY OF CHANGES

1. The bid opening date has not changed.

2. BID SCHEDULE NOTE #4 UPDATE

4. NOTICE TO LARGE BUSINESS: The U.S. Army Corps of Engineers, St. Paul District, is committed to participation of Small Business, Small Disadvantaged Business and Women-Owned Small Business in the performance of work under this solicitation and resultant contract.

Your attention is directed to the solicitation clauses 52.219-0008 entitled "Utilization of Small Business Concerns", 52.219-0009 I entitled "Small Business Subcontracting Plan," and 252.219-7003 entitled "Small, Small Disadvantaged and Women-Owned Small Business Subcontracting Plan (DOD Contracts)".

If you are a large business and the apparent low bidder with a bid exceeding \$1,000,000, submission of a Subcontracting Plan in accordance with above clauses will be required. The Contracting Officer will review the plan using the following goals to assure that it represents your best efforts to maximize subcontracting opportunities. Award will not be made until the Contracting Officer approves the Subcontracting Plan.

The following subcontracting goals are informational only and not legally binding but are considered reasonable and achievable during the resultant contract from this solicitation. The goals expressed in percent of total planned subcontracting dollars are:

Small Business	57.2%
Small Disadvantaged Business	8.9%
Women-Owned Small Business	8.1%
HUBZone Small Business	3.0%
Veteran-owned Small Business	3.0%
Subcontract Reporting (SF 294 & SF 295)	100.0%

3. TECHNICAL CHANGES

Drawing M-L1-56/002, sheet 167 of 168, change Note 3, cable information to read as follows:

CABLE:

- (50) PAIR, RODENT RESISTANT, DIRECT BURY COMMUNICATIONS CABLE, COPPER 22-AWG TWISTED PAIR, 300-VOLT INSULATION; CORE ASSEMBLY FILLED WITH 80-DEG C, ETPR COMPOUND; NON-HYGROSCOPIC DIELECTRIC TAPE OVER CORE ASSEMBLY; CORRUGATED MOISTURE/GOPHER RESISTANT COPPER ALLOY OR COPPER CLAD STEEL TAPE APPLIED HELICALLY, OR LONGITUDINALLY WITH OVERLAP OVER THE CORE ASSEMBLY; BLACK POLYETHYLENE OVERALL OUTER JACKET. SUPERIOR-ESSEX GOPIC-F OR GOPIC-FSF OR EQUAL.

- ADDITIONAL 400' SPOOL OF 3-PAIR, RODENT RESISTANT, DIRECT BURY COMMUNICATIONS CABLE, COPPER 22-AWG TWISTED PAIR, 300-VOLT INSULATION; CORE ASSEMBLY FILLED WITH 80-DEG C, ETPR COMPOUND; NON-HYGROSCOPIC DIELECTRIC TAPE OVER CORE ASSEMBLY; CORRUGATED MOISTURE/GOPHER RESISTANT COPPER ALLOY OR COPPER CLAD STEEL TAPE APPLIED HELICALLY, OR LONGITUDINALLY WITH OVERLAP OVER THE CORE ASSEMBLY; BLACK POLYETHYLENE OVERALL OUTER JACKET. SUPERIOR-ESSEX BSW G OR EQUAL.

Drawing M-L1-56/001, Sheet 166 of 168:

In Amendment 4, the following was added to the notes:

“6 ALL EXISTING ELECTRICAL EQUIPMENT THAT IS ABANDONED OR TAKEN OUT OF SERVICE SHALL BE THE PROPERTY OF THE CONTRACTOR AND REMOVED FROM GOVERNMENT PROPERTY.”

Please remove this sentence and replace with the following:

“6 ALL EXISTING ELECTRICAL EQUIPMENT THAT IS ABANDONED OR TAKEN OUT OF SERVICE, BY THE CONTRACTOR, SHALL BE THE PROPERTY OF THE CONTRACTOR AND REMOVED FROM GOVERNMENT PROPERTY.”